



The Balasore Bhadrak Central Co-operative Bank Ltd.
Head Office: O.T. Road, Balasore-756001

Letter No./BBCCB/ Computer/ 8866 /2023-24/

Dt. 12.02.24

TENDER CALL NOTICE

Sealed Quotations are invited from reputed firm/ Electrical contractor having valid G.S.T./ I.T. clearance certificate for supply and install 03 nos of chemical earthing at Head Office and 30 nos in different Branches of BBCC Bank with the terms & conditions which may be referred from the Bank's website (www.bbccbalsore.com).

The quotations should be submitted in the name cover of the Chief Executive Officer of the Bank on or before 2.00 P.M. of 22.02.2024 which will be opened at 4.00 P.M. on the same day by the Purchase Committee of the Bank in presence of quotationers or their authorized representative.

The authority reserves the right to reject any or all the quotations without assigning any reason there of and shall not be bound to accept the lowest quoted price.

[Handwritten signature]
[Handwritten name]

Chief Executive Officer

Memo No. 8867 /Dt.

Copy to the daily News Editor, Sakala, Balasore & Bhadrak for publication in daily news paper.
Copy to the Notice Board of Head Office/All Branches/Bank website for information and necessary action.

[Handwritten signature]
[Handwritten name]

Chief Executive Officer

Memo No. 8868 /Dt.

Copy to Sri H.S. Dash, (DGM)/ Sri A. Mohanty, (AGM, Loans) /Sri. B.K. Kar, (AGM, Legal) /Sri S.K. Das, (Manager, HRD) / Sri S.K. Biswal (AGM, Accounts) of the Bank for information and necessary action with a request to attend the Purchase Committee meeting on dt- 22.02.2024 at 4.00 P.M.

[Handwritten signature]
[Handwritten name]

Chief Executive Officer





The Balasore Bhadrak Central Co-operative Bank Ltd.
Head Office, O.T. Road, Balasore-756001

DETAILS OF WORK PLACE

SL No	Branch Name	Address of Branch	Chemical Earthing Required(nos)
1	Main Br. Bls	At/Po- O.T Road, Balasore-756001	1
2	Remuna	At/Po- Remuna, Balasore-756019	1
3	Basta	At/Po- Basta, Balasore-756029	1
4	Baliapal	At/Po- Baliapal, Balasore-756026	1
5	Jaleswar	At/Po- Jaleswar, Balasore-756032	1
6	Bhogarai	At/Po- Chandaneswar, Balasore-756085	1
7	Nilagiri	At/Po- Raj-Nilagiri, Balasore-756040	1
8	Bahanaga	At/Po- Gopalpur Balasore-756044	1
9	Soro	At/Po- Soro, Balasore-756045	1
10	Simulia	At/Po- Markona, Balasore-756126	1
11	Khaira	At/Po- Khaira, Balasore-756048	1
12	Basudevpur	At/Po- Basudevpur, Bhadrak -756125	1
13	Bhadrak	At/Po- Bhadrak, Bhadrak-756100	1
14	Bonth	At/Po- Bonth, Bhadrak- 756114	1
15	Dhamanagar	At/Po- Dhamanagar, Bhadrak- 756117	1
16	B.Pokhari	At/Po- BhandariPokhari, Bhadrak-756120	1
17	Tihidi	At/Po- Tihidi, Bhadrak- 756130	1
18	Chandbali	At/Po- Chandabali, Bhadrak -756133	1
19	Town Br.	At-Vivekananda Marg, Po- Srikanthapur, Balasore-756003	1
20	Oupada	At/Po- Oupada, Balasore-756049	1
21	Mahila Br.	At/Po- Azimabad, Balasore-756001	1
22	Balaramgadi	At/Po- Balaramgadi, Chandipur, Balasore-756025	1
23	Januganj	At/Po- Januganj, Balasore-756019	1
24	Bahabalpur	At/Po- Bahabalpur, Haladipada, Balasore-756027	1
25	Kupari	At/Po- Kupari, Balasore-756059	1
26	Charampa	At/Po- Charampa, Bhadrak -756101	1
27	Dhamara	At/Po- Dhamara, Bhadrak- 756171	1
28	Agarpada	At/Po- Agarpada, Bhadrak -756115	1
29	Kalipada	At-Kalipada, Po- Jagai, Balasore-756083	1
30	Jls Evng.	At/Po- Jaleswar, Balasore-756032	1
31	Head Office	At/po-F.M Golei, OT Road, Balasore-756001	3

Total 33





The Balasore Bhadrak Central Co-operative Bank Ltd.
Head Office, O.T. Road, Balasore-756001

Works to be carried out:-

Sl	Description of the work
1.	Pit Size- The depth of the pit should be at least 3000 mm, and the width lengths should be 450mm in size. (450x450x3000)
2.	Chemical Mixture- Bentonite, Salt, and Charcoal is to be used for retaining moisture and increases the conductivity of the chemical mixture.
3.	Earth Resistance- The Earth Resistance of Chemical Earthing should be less than 1 Ohm, which ensures a low-impedance path for electrical currents to flow to the earth.
4.	Electrode Material- Electrode Material used in Chemical Earthing should be of GI (Galvanized Iron) for high conductivity and resistant to corrosion. Size:- Legth of rod- 10 ft. Outer Dia- 40 mm Colour- Silver Terminal Hole- 12 mm
5.	GI flat- Thickness- 19mm x 3mm Make:- ISI mark (Tata/Jindal)
6.	The Electrode to be placed at 1ft above the ground level and 9 ft under the ground and the pit should be covered/sealed with concrete at ground level.
7.	GI Flat conductor wiring to be provided from Earthing point to panel board.

Terms & Conditions :

1. Performance security i.e. 5% of the final order value to be submitted by the L1 Contractor within 07 days on receipt of work order from the bank. The performance security will be returned after six months of successful completion of the work and certificate from the consultant Engineer.
2. Bills should be submitted within 07 days on successful completion of the work along with work completion certificate, certified by the electrician of our Bank.
3. All the workmen/women power to be engaged by the contractor should be covered under the statutory government regulation framed from time to time. The contractor will abide by all the statutory rules & regulation relating to Labour law, accident, workmen compensation act, workmen insurance, ESI, PF etc. this will be the sole responsibility of the contractor & bear all the expenses there of. Bank will not be a party at any stage to any kind of dispute relating to the above. In case any liability arises due to non performance by the contractor, under no circumstances, the Bank shall be liable for the same.
4. The contractor will provide for all necessary material, tools, equipment & working consumables etc. needed for execution of the work, safe custody of all such equipment/ materials will be Contractor's entire responsibility. No extra charge will be paid for the same.





The Balasore Bhadrak Central Co-operative Bank Ltd.
Head Office, O.T. Road, Balasore-756001

5. The job should be completed within 60 days from the issue of work order, otherwise 2% penalty will be charged on each defaulted date.
6. All the workmen/staff of the contractor shall bear photo identity card during the period of work which will be duly signed by the representative of the organization/ Agency.
7. Any damage/pilferage to the Bank property due to mishandling, carelessness of the contractor by his workmen will recoverable from the contractor's bill.
8. Contractor should ensure cleaning of the waste/ dusts due to the work on day to day basis and minimum obstruction to passage for bank customers and employees.
9. Any dispute arising out of terms and condition shall be subjected to the Jurisdiction Balasore.
10. All the work with specification will be certified by the Branch Managers.

Asis
Mohanty

Chief Executive Officer

